



December 12, 2012

Mr. John Baird
Assistant Superintendent for Operations
Community School District #303
901 Peck Road
St. Charles, Illinois 60174

**RE: Radon Measurement Surveys – Community School District #303 Facilities
Carnow Conibear Project No.: A135560061**

Dear Mr. Baird:

Carnow, Conibear, & Assoc., Ltd. (Carnow Conibear) was contracted by Community School District #303 (CUSD #303) to perform radon measurement surveys at twenty-two CUSD #303 school facilities located in St. Charles, Illinois. The surveys were conducted from October 1, 2012 thru November 29, 2012 by an Illinois Emergency Management Agency (IEMA) licensed Radon Measurement Professional. The scope of work included short term (two to four day) radon measurements in frequently occupied rooms with substantial ground contact. All radon sampling was performed following IEMA and the United States Environmental Protection Agency (USEPA) testing protocols for commercial and school radon measurements, the radon device manufacturer's recommendations, and Carnow Conibear's Quality Assurance Plan.

Over 1,500 radon samples were collected in both occupied and unoccupied areas. Activated radon charcoal devices manufactured by Air Chek Inc. were utilized. All regularly occupied student, teacher, and employee locations tested were below the EPA and IEMA recommended action level of 4.0 pCi/L.

We appreciate the opportunity to assist CUSD #303 on this important project. Please do not hesitate to contact me at (312) 762-2928 if you have any questions or need additional information.

Sincerely,

CARNOW, CONIBEAR & ASSOC., LTD.

A handwritten signature in blue ink, appearing to read "David J. Kedrowski".

David J. Kedrowski, CIH
Executive Vice President